



# NOTES:

1. PVC EXTENSIONS SHALL BE USED ON VALVE BOX INSTALLATION.
2. THE ACTUATING NUT FOR DEEPER VALVES SHALL BE EXTENDED TO COME UP TO BETWEEN 2' & 4' DEPTH BELOW FINISHED GRADE. EXTENSION STEM SHALL BE PERMANENTLY ATTACHED TO VALVE ACTUATOR.
3. VALVE BOXES SHALL BE EITHER 2 OR 3 PIECES, DEPENDING ON DEPTH. THERE SHALL BE A TOP SECTION WITH A COVER APPROPRIATELY LABELED FOR THE SERVICE USE AND A BOTTOM BELL SECTION WHICH FITS OVER THE ACTUATOR NUT ON BEDDING ROCK. IF REQUIRED FOR EXTENSION CAST IRON SOIL PIPE MAY BE USED.

## **VALVE AND BOX DETAIL**

VALVES 14" AND SMALLER