



- NOTES**
1. PVC EXTENSIONS SHALL NOT BE USED ON VALVE BOX INSTALLATION
 2. ALL WATER SHUT-OFF VALVES SIXTEEN INCHES AND LARGER SHALL BE BUTTERFLY VALVES
 3. VALVE OPERATOR NUTS SHALL BE BETWEEN 2'-3' BELOW GRADE. IF OPERATOR NUTS ARE GREATER THAN 3' BELOW FINISH GRADE EXTENSION STEMS SHALL BE INSTALLED. SEE DETAIL FOR VALVE EXTENSION STEMS IN VOLUSIA COUNTY FIGURES & DETAILS.

BUTTERFLY VALVE AND BOX DETAIL

FOR 16" AND LARGER VLAVES