



- NOTES:
1. ALL PIPE & FITTINGS ABOVE GRADE SHALL BE FLANGED
  2. ALL PIPING, FITTINGS AND SUPPORTS TO BE PAINTED. COLOR TO BE SELECTED BY COUNTY.
  3. DOUBLE CHECK DETECTOR ASSEMBLY SHALL HAVE A FUSED EPOXY COATED CAST IRON BODY.
  4. ASSEMBLY SHALL BE EQUIPPED WITH A LOW FLOW METERING DEVICE TO DETECTED LEAKS.

## **DOUBLE DETECTOR CHECK ASSEMBLY**