



NOTES:

1. PVC EXTENSIONS SHALL BE USED ON VALVE BOX INSTALLATION.
2. THE ACTUATING NUT FOR DEEPER VALVES SHALL BE EXTENDED TO COME UP TO BETWEEN 2' & 4' DEPTH BELOW FINISHED GRADE. EXTENSION STEM SHALL BE PERMANENTLY ATTACHED TO VALVE ACTUATOR.
3. VALVE BOXES SHALL BE EITHER 2 OR 3 PIECES, DEPENDING ON DEPTH. THERE SHALL BE A TOP SECTION WITH A COVER APPROPRIATELY LABELED FOR THE SERVICE USE AND A BOTTOM BELL SECTION WHICH FITS OVER THE ACTUATOR NUT ON BEDDING ROCK. IF REQUIRED FOR EXTENSION CAST IRON SOIL PIPE MAY BE USED.
4. LOCATING WIRE SHALL BE CONTINUOUS INSIDE THE VALVE BOX AND SHOULD EXTEND 12" ABOVE TOP OF COLLAR. WIRE SHALL BE COLOR CODED TO MATCH THE UTILITY INSTALLED

VALVE AND BOX DETAIL

UPDATED MARCH 2014

VALVES 14" AND SMALLER