



NOTES

1. STORM DRAIN MAY BE LOCATED ON EITHER SIDE OF ROAD.
2. SANITARY SEWER SERVICES ARE TO BE LAID OVER OR UNDER STORM DRAINS AS REQUIRED.
3. SANITARY SERVICE LATERAL SHALL HAVE A MINIMUM SLOPE OF 0.01%.
4. SANITARY SEWER IS TO BE A MINIMUM OF 6" DIA.
5. 18" SEPARATION SHALL BE MAINTAINED BETWEEN ALL PIPES WHEN POSSIBLE.

TYPICAL UNDERGROUND UTILITIES LOCATION