



#### NOTES:

1. FIRE HYDRANT TO BE LOCATED 6' TO 8' FROM EDGE OF PAVEMENT.
2. VALVE BOX SHALL BE SCREW TYPE ADJUSTABLE AND COVER SHALL BE MARKED: WATER.
3. FIRE HYDRANTS CANNOT BE LOCATED WITHIN THE RADIUS OF STREET CORNERS.
4. FIRE HYDRANT 3' RADIUS MUST BE CLEARED FOR SHRUBS
5. FIRE HYDRANT SHALL BE SUPPLIED WITHOUT WEEP HOLE, OR WITH A PERMANENTLY PLUGGED WEEP HOLE.
6. FIRE HYDRANT SHALL MEET VOLUSIA COUNTY SPECIFICATIONS.
7. ALL FIRE HYDRANT PIPING SHALL BE RESTRAINED BY MEGA-LUGS.
8. LOCATE WIRE AND LOCATE TAPE (TWO TYPES) SHALL BE ON ALL PIPES.
9. A BLUE REFLECTOR SHALL BE INSTALLED ON THE PAVEMENT ADJACENT TO THE FIRE HYDRANT.

## **FIRE HYDRANT ASSEMBLY DETAIL**

N.T.S.