

VOLUSIA COUNTY

Landscape and Irrigation Compliance Certification and Checklist

(Each item must be filled in or checked and contractor(s) signature and date is required)

Development Address _____ Address _____
_____ Permit Number _____

Irrigation Standards

- High-volume irrigation area does not exceed 50% of the open space, or 75% if 25% of pre-existing native vegetation is retained onsite.
- Medium-volume irrigation area does not exceed 25% of the open space, or 75% of the open space if there is no high volume irrigation installed.
- All sprinkler heads installed are pressure regulating heads

___ Equipment with check valves must be used in low-lying areas to prevent low head drainage

- No sprinklers less than 4-inches from pavement
- No sprinklers less than 12-inches from structures

_ Spray patterns provide head to head coverage

- Spray heads and rotors are not mixed in the same lawn irrigation zone

_ Sprinklers do not spray water onto paved surfaces and buildings

_ A functioning rain shutoff device is evident and exposed to unobstructed rainfall

- An approved backflow preventer is properly installed

_ Reclaimed or non-potable water is used for irrigation if available

_ Irrigation design is with the appropriate uniformity for the type of plant being grown and the type of soil

_ A landscape maintenance checklist and information package is provided to the property owner

- An as-built sketch of the irrigation system is provided for property owner

I hereby certify that the abovementioned standards have been met and installed on this project.

Irrigation Contractor (Print Name)

License Number

Date

Signature

DRAFT