

Examples of Common Safety Violations



Unsecured compressed cylinders.



Blocked electrical panel.

this unit and two pars tags should be displayed on this passport. According to this passport, there should be five members reporting.



Fire extinguishers are considered compressed cylinders and should be secured from falling.



Store paints and chemicals in proper locations. Do not store inside the living area.



Label containers with the appropriate chemical being used for example, window cleaner, degreaser, or Armor All.



Rated fire doors shall be closed at all time.