



- NOTES:
1. ALL PIPE & FITTINGS ABOVE GRADE SHALL BE FLANGED
  2. ALL PIPING, FITTINGS AND SUPPORTS TO BE PAINTED. COLOR TO BE SELECTED BY COUNTY.
  3. DOUBLE DETECTOR CHECK ASSEMBLY SHALL HAVE A FUSED EPOXY COATED CAST IRON BODY.
  4. ASSEMBLY SHALL BE EQUIPPED WITH A LOW FLOW METERING DEVICE TO DETECT LEAKS.

## **DOUBLE DETECTOR CHECK ASSEMBLY**

FOR FIRE PROTECTION ONLY

UPDATED NOVEMBER 2018