



NOTES

1. PVC EXTENSIONS SHALL NOT BE USED ON VALVE BOX INSTALLATION
2. ALL WATER SHUT-OFF VALVES SIXTEEN INCHES AND LARGER SHALL BE BUTTERFLY VALVES
3. VALVE OPERATOR NUTS SHALL BE BETWEEN 2'-3' BELOW GRADE. IF OPERATOR NUTS ARE GREATER THAN 3' BELOW FINISH GRADE EXTENSION STEMS SHALL BE INSTALLED. SEE DETAIL FOR VALVE EXTENSION STEMS IN VOLUSIA COUNTY FIGURES & DETAILS.
4. LOCATING WIRE SHALL BE CONTINUOUS AND SHOULD EXTEND 12" ABOVE TOP OF COLLAR. WIRE SHALL BE COLOR CODED TO MATCH THE UTILITY INSTALLED

BUTTERFLY VALVE AND BOX DETAIL

FOR 16" AND LARGER VALVES

UPDATED JUNE 2016