

VOLUSIA COUNTY

Landscape and Irrigation Compliance Certification and Checklist

(Each item must be filled in or checked and contractor(s) signature and date is required)

Development _____ Address _____
Permit Number _____

Irrigation Standards

- ___ High-volume irrigation area does not exceed 50% of the open space
- ___ Medium-volume irrigation area does not exceed 25% of the open space
- ___ Low-volume irrigation area does not exceed 25% of the open space
- ___ Organic mulch is at least 3-inches deep on all beds
- ___ All sprinkler heads installed are pressure regulating heads
- ___ No sprinklers less than 4-inches from pavement
- ___ No plants planted or spray irrigation applied under roof over hangs
- ___ Micro-irrigation is used for all tree/shrub/groundcover beds
- ___ Spray patterns provide head to head coverage
- ___ Spray heads and rotors are not mixed in the same lawn irrigation zone
- ___ Plants are installed so they do not interfere with irrigation spray coverage
- ___ Turfgrass, annual flowers and vegetable gardens are on separate irrigation zones from tree, shrub and groundcover beds
- ___ Sprinklers do not spray water onto paved surfaces and buildings
- ___ A functioning rain shutoff device is evident and exposed to unobstructed rainfall
- ___ An approved backflow preventer is properly installed
- ___ Reclaimed or non-potable water is used for irrigation if available (NA if not available)
- ___ A landscape maintenance checklist and information package is provided to the property owner
- ___ A generalized sketch of the irrigation system is provided for property owner

I hereby certify that the abovementioned standards have been met and installed on this project.

Irrigation Contractor (Print Name)

License Number

Date

Signature